

General Notes to the LV Switchgear Vendor List

1. This Vendor list is issued by Chairman, ADDC Low Voltage Switchgear Committee.
2. Any LV Equipment that is installed in Abu Dhabi need to be prequalified by ADDC, through the LV Switchgear Committee as per the Guidelines
3. All the Pre-qualified Vendors are authorized to supply only the approved product ratings.
4. All the Pre-qualified Vendors are not allowed to supply non approved materials. Failure to comply may result in disqualify of their name from the Vendor list.
5. The above approval does not relieve the Contractors in complying with RSB guidelines and ADDC standards that are applied to the LV products.
6. This Vendor list will be updated periodically by the Low Voltage Switchgear Committee.
7. Validity of the Prequalification issued for a Vendor is for period of three (3) years from the date of issue of the approval letter issued by the LV Switchgear Committee, unless otherwise specified.
8. It is the responsibly of the manufacturer to comply with any updated IEC standards that would be released during this period by means of additional test as required.
9. Any malfunction or repeated faults during this period may lead to the disqualification of the approved products.
10. All breakers (both incoming and outgoings) shall be restricted to the components used in the type test.
11. All breakers used in the switchgear shall be type tested separately by the manufacturer as per the latest IEC standards.
12. The ADDC approved Vendors of the Final Distribution Board are authorized to assemble and supply the Consumer Unit provided that they use the same cross section of the type tested final DB except the fact that it will be a single bus bar construction. Separate prequalification is not required for the consumer unit.
13. ADDC LV Switchgear Committee advice all Vendors of LV Switchgear shall comply with the latest IEC 61439 standard.

14. It shall be the responsibility of the Supplier to propose the most appropriate products which are prequalified and that suit the application of the end user. Certain prequalified products may not be suitable for special applications and end users are advised to clarify the same with suppliers.






15. Any Vendors who are not included in this list and hold a valid approval from ADDC Low Voltage Switchgear Committee which is issued at a later date to the publication of this Vendor list are also authorized to supply their approved products in Abu Dhabi. Their name will be added in the next revision of the Vendor List.





16. All approved panel assembly must align the main horizontal busbar at the top of the panel if the panel is installed in the basement of the building. Separate approval from ADDC Inspection Section must be obtained in all other cases.






17. It is the responsibility of approved manufacturers/suppliers to keep their customers aware of the special conditions stated in the test reports that restrict the use of the approved materials at different connection environment.


18. Any discrepancy in the prequalified products description shall be notified to the ADDC Low Voltage Switchgear Committee in the following Address.




**Chairman,
ADDG Low Voltage Switchgear Committee,
Abu Dhabi Distribution Company
P O Box 219,
Abu Dhabi, U A E.
Email: lvsgc@addc.ae**





1	A	B	C	D	E	F	G					
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List										
3		Manufacturer Name & Address										
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		ADDC Approval Letter Reference		Date of Approval / Expiry					
5			Product Reference	Current Rating/ Busbar Size								
6	A Product Group LV01 - MDB, SMDB and Final DB											
7	9	Al Hamad Industries International		P.O. Box Tel: 06-7407778, Fax: 06-740 7766								
8	 DIVISION OF AL HAMAD INDUSTRIES	Dunes 500: 5000A MDB Form IV Type 6 Incomer ACB	4000A 3x120x10	QCC APPROVAL LETTER		4-Feb-2018	3-Feb-2019					
9		Dunes 320: 3200A MDB Form IV Type 6 Incomer ACB	3200A 3x120x10									
10		Dunes 250: 2500A MDB Form IV Type 6 Incomer ACB	2500A 2x100x10									
11		Dunes 160: 1600A MDB Form IV Type 6	1600A 2x60x10									
12		Dunes 125: 1250A MDB Form IV Type 6	1000A 2x50x10									
13		800A SMDB MCCB	800A 1x50x10									
14		400A SMDB MCCB	400A 1x30x10									
15		250A SMDB MCCB	250A 1x20x10									
16		10	Al Ishraf Corner Electric Switchgear LLC					P.O. Box Tel: 02-5503774, Fax: 02-550 6277				
17			2500A PANELS/MDB/ SMDB/MCC (2500A ACB Schneider)					2500A 4x100x5	ADDC/LVSGC/16/ 2308397475 & 6160474874		12-Jan-2017	12-Jan-2020
18	1000A PANELS/MDB/ SMDB/MCC (1250A MCCB Schneider)		1000A 2x50x10									
19	600A PANELS/MDB/ SMDB/MCC/ ATS/ISOLATOR (630A MCCB Schneider)		600A 2x30x5									
20	250A PANELS/MDB/ SMDB/MCC (250A MCCB Schneider)		250A 1x30x5									
21	1600A PANELS/MDB/ SMDB/MCC (1600A ACB Schneider)		1600A 4x60x5									
22	800A PANELS/MDB/ SMDB/MCC (MCCB Merlin Gerin)		800A 1x50x10									
23	400A PANELS/MDB/ SMDB/MCC (MCCB Merlin Gerin)		400A 1x25x10									
24	11	Al Fanar Electric LLC		P.O. Box Tel: 04-267 7500, Fax: 04-267 8197								
25		250A 3 PHASE SMDB/MCC with 250A MCCB, Schneider Make	250A 2x20x5	ADDC/LVSGC/16/2446245289		1-Feb-2016	1-Feb-2019					
26		400A 3 PHASE SMDB/MCC with 250A MCCB, Schneider Make	400A 3x20x5									
27		630A 3 PHASE SMDB/MCC with 600A MCCB, Schneider Make	600A 4x20x5									
28		800A 3 PHASE SMDB/MCC with 800A MCCB, Schneider Make	800A 2x50x5									
29		1600A 3 phase MDV/ LVP/MCC with 1600A MCCB, Schneider Make	1600A 2x60x10									
30		2500A 3 phase MDB/LVP/MCC with 2500A MCCB, Schneider Make	2500A 2x100x10									
31	12	Al Rebou Electrical Switchgear Assembly L.L.C.		Tel: 06-534 7678, Fax: 06-534 7698								
32		250A MDB 6 Way Panel; TP MCCB, Merlin Gerin	250A 1x25x10	QCC APPROVAL LETTER		14-Sep-17	13-Sep-18					
33		400A DB With 400A MCCB (ABB)	400A 1x30x10									
34		800A DB With 800A MCCB (EATON CH)	800A 1x50x10									
35		1600A MDB 5 Way Panel; TP ACB, Merlin Gerin	1600A 2x60x10									



1	A	B	C	D	E	F	G	
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List						
3		Manufacturer Name & Address						
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		Current Rating/ Busbar Size	ADDC Approval Letter Reference	Date of Approval / Expiry	
5		Product Reference	Current Rating/ Busbar Size	ADDC Approval Letter Reference	Date of Approval / Expiry			
6	A Product Group LV01 - MDB, SMDB and Final DB							
7	13	Al Terhab Electrical Switchgear Dist. LLC			Tel: 06-534 5388, Fax: 06-534 5385			
8		2500A Main Distribution Board Form 4b (ACB ABB SACE)	2500A 2 x 100 x 10	QCC APPROVAL LETTER	12-Dec-17	11-Dec-18		
9		1600A Main Distribution Board Form 4b (ACB ABB SACE Exam)	1600A 2 x 60 x 10					
10	14	Arabian Gulf Switchgear Ltd			Tel: 02-627 3050, Fax: 02-627 3661			
11	 AGS Arabian Gulf Switchgear	AGS SWB32 MDB, 4000A TP Draw out ACB type NW40H2 Schneider Electric make	3200A 5 x 125 x 5	QCC APPROVAL LETTER	26-Nov-17	25-Nov-18		
12		AGS SWB25 MDB, 3200A TP Draw out ACB type NW32H1 Schneider Electric make	2500A 4 x 100 x 5					
13		AGS SWB25 MDB, 2000A TP Draw out ACB type NW20H2 Schneider Electric make	1600A 2 x 100 x 5					
14		AGS Switchboard type 3 (1000A), MCCB type NS1250N Schneider Electric make	1000A 1 x 80 x 10					
15		AGS Switchboard type 3 (630A), SMDB MCCB Schneider Electric make	630A 1 x 40 x 10					
16	15	Arabian Sea Dynamic & Switchgear			Tel: 03-735 4508, Fax: 03-735 4509			
17	Arabian Sea Dynamic & Switchgear	400A SMDB With 400A MCCB (Schneider) , 36kA / 1 Sec	400A 1 x 30 x 10	ADDC/LVSGC/16/8975852541	15-Nov-16	15-Nov-19		
18		600A SMDB With 630A MCCB (Schneider) , 36kA / 1 Sec	600A 1 x 40 x 10					
19		1000A SMDB With 1000A MCCB (Schneider) , 50kA / 1 Sec	1000A 2 x 40 x 10					
20		2500A SMDB With 1000A ACB (Schneider) , 50kA / 3 Sec	2500A 2 x 100 x 10					
21	16	Bin Ghalib Engineering			Tel: 02-679 4026, Fax: 02-679 5934			
22		L-Shape 2500A Panel with Bottom Busbar	2500A 2 x 90 x 10	ADDC/LVSGC/16/2968995086	25-Oct-2016	25-Oct-2019		
23		Panel Board 250A	250A 1 x 20 x 10	ADDC/LVSGC/17/5825073385	12-Feb-2017	11-Feb-2020		
24		Panel Board 400A	400A 1 x 30 x 10					
25		LV Panel 5000A Form 4b Extendable ACB Schneider make	5000A 2x2x12x90	ADDC/LVSGC/17/1286822261	12-Feb-2017	11-Feb-2020		
26		LV Panel 800A ABB TP MCCB Bottom Busbar	800A 2 x 12 x 42	ADDC/LVSGC/17/3596054582	12-Feb-2017	11-Feb-2020		
27		LV Panel 1000A ABB TP ACB Bottom Busbar	1000A 2 x 12 x 42					
28		LV Panel 1600A ABB TP ACB Bottom Busbar	1600A 2 x 12 x 54					
29		2500A MDB	2500A	QCC APPROVAL LETTER	12-Nov-17	11-Nov-18		
30		2500A TP ACB ABB make E3N25	2 x 90 x 12					
31		6000A LOGSTRUP MODULAR ASSEMBLY FORM 4b ABB	6500A 2*2 12mm x 144 mm	QCC APPROVAL LETTER	12-Nov-17	11-Nov-18		


1	A	B	C	D	E	F	G	
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List						
3		Manufacturer Name & Address						
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		Current Rating/ Busbar Size	ADDC Approval Letter Reference	Date of	
5			Product Reference	Approval /			Expiry	
6	A Product Group LV01 - MDB, SMDB and Final DB							
7	17	Bloudan Control System Ind.L.L.C			Tel: 04-339 0499, Fax: 04-3391 553			
8	 BLOUDAN CONTROL	800A ELSTEEL TECHNO MODULE FORM 4b with 800A MCCB ,4P ,ABB MAKE	730A	ADDC/LVSGC/16/99	13-Oct-2016	13-Oct-2019		
9		1600A ELSTEEL TECHNO MODULE FORM with 1600A ACB ,4P ,ABB MAKE	2 x 20 x 10					
10		2500A ELSTEEL TECHNO MODULE FORM with 2500A ACB ,4P ,ABB MAKE	1600A					
11		3200A ELSTEEL TECHNO MODULE FORM with 3200A ACB ,4P ,ABB MAKE	2 x 60 x 10					
12	18	CastleRock Elect.Switchgear			Tel: 06-535 1573			
13	 CASTLEROCK ELECT. SWITCHGEAR	MCS 2500A System TP ACB .ABB	2500A	ADDC/LVSGC/17/8989757373	12-Feb-2017	11-Feb-2020		
14			2 x 100 x 10					
15	19	Connect Switchgear Assembly L.L.C			Tel: 06-535 8788, Fax: 06-535 8789			
16	 CONNECT SWITCHGEAR	Lateefa TT 4000A MDB with 4000A ACB/MCCB(Schneider)	4000A	ADDC/LVSGC/16/4295029430	12-Jan-2017	12-Jan-2020		
17		Lateefa TT 2500A MDB with 2500A ACB/MCCB(Schneider)	4 x 120 x 10					
18		Lateefa TT 1600A MDB with 1600A ACB/MCCB(Schneider)	2500A					
19		Lateefa TT 800A SMDB with 8000A MCCB(Schneider)	2 x 100 x 10					
20		Lateefa TT 400A SMDB with 400A MCCB(Schneider)	2 x 60 x 10					
21	20	Dorman Smith Switchgear LLC			P.O. Box Tel: 04-347 0226, Fax: 04-347 0002			
22	 DORMAN SMITH	Loadcenter Split-Load MCB Distribution Boards 1x6 way and 1x14 way with 100A Isolator and RCCB, Dorman Smith Make	100A	QCC APPROVAL LETTER	4-Feb-2018	3-Feb-2019		
23		Loadbank 125,250 MCCB , Dorman Smith	3x10x2					
24		Loadbank 125,400 MCCB PANEL . Dorman smith	250A					
25		Loadbank 250,400 MCCB PANEL . Dorman smith	1x25x5					
26		Loadbank 250,800 MCCB PANEL . Dorman smith	400A					
27		Modis 25 Ultra 2500A ACB Dorman Smith	2x25x5					
28		400A						
29			1x50x6					
30			800A					
31			1x80x6					
32			2500A					
33			2x100x10					





1	A	B	C	D	E	F	G				
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List									
3		Manufacturer Name & Address									
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		Current Rating/ Busbar Size	ADDC Approval Letter Reference	Date of				
5			Product Reference	Approval /			Expiry				
6	A Product Group LV01 - MDB, SMDB and Final DB										
7	24	Engineering Solution Switchgear Factory			Tel: 02- 554 4815, Fax: 02-554 4814						
8		ESS DB 250A SMDB with 400A Non Extendable MCCB , Siemens	250A 1 x 30 x 10	ADDC/LVSGC/17/1332911781	23-Feb-2017	22-Feb-2020					
9		ESS DB 400A SMDB With 630ANon Extendable MCCB , Siemens	400A 1 x 30 x 10								
10		ESS DB 630A SMDB With 800ANon Extendable MCCB , Siemens	800A 1 x 40 x 10								
11	25	EUROTECH FZCO		P.O. Box	Tel: 04-883 0333, Fax: 04-883 0339						
12	EUROTECH FZCO	125A MICROPAN DB With 125A MCB (Schneider)	125A 1x15x3	QCC APPROVAL LETTER	3-May-2018	2-May-2019					
13		250A MICROPAN DB With 250A MCCB (Schneider)	125A 1x15x5								
14			250A SMDB TYPE A with 250A MCCB (Schneider) Bottom cable entry , IP 54	250A 2x20x5	ADDC/LVSGC/16/8375138600 & 1207357764	12-Jan-2017	12-Jan-2020				
15			250A SMDB TYPE B with 250A MCCB (Schneider) Bottom cable entry , IP 44	250A 2x20x5							
16			EUROFORM 250A MDB/SMDB/MCC (250A MCCB Schneider)	250A 30 x 10	QCC APPROVAL LETTER	3-May-2018	2-May-2019				
17			EUROFORM 630A MDB/SMDB/MCC (630A MCCB Schneider)	630A 50 x 10							
18			400A SMDB TYPE A With 400A MCCB(Schneider) Bottom Cable Entry, 42 Ka / 1 Sec	380A 2 x 30 x 05	ADDC/LVSGC/16/9274441408	5-Dec-2016	5-Dec-2019				
19			400A SMDB TYPE B With 400A MCCB(Schneider) Bottom Cable Entry, 42 Ka / 1 Sec	400A 2 x 30 x 05							
20			630A SMDB TYPE A With 630A MCCB(Schneider) Bottom Cable Entry, 50 Ka / 1 Sec	600A 2 x 30 x 06 1 x 30 x 05							
21			630A SMDB TYPE B With 630A MCCB(Schneider) Bottom Cable Entry, 50 Ka / 1 Sec	550A 2 x 30 x 06 1 x 30 x 05							
22			800A SMDB TYPE A With 800A MCCB(Schneider) Bottom Cable Entry, 50 Ka / 3 Sec	800A 1 x 60 x 10							
23			800A SMDB TYPE B With 800A MCCB(Schneider) Bottom Cable Entry, 50 Ka / 3 Sec	785A 1 x 60 x 10							
24			250A GIGAPAN SMDB with 250A MCCB, Schneider Make	250A 1x40x5				QCC APPROVAL LETTER	3-May-2018	2-May-2019	
25			400A GIGAPAN SMDB with 400A MCCB, Schneider Make	400A 1x60x5							
26			630A GIGAPAN SMDB with 630A MCCB, Schneider Make	630A 2x50x5							
27		800A GIGAPAN SMDB with 800A MCCB, Schneider Make	800A 2x50x5								
28		1000A MDB with 1000A ACB, TP Merlin Gerin Make	1000A 1x80x10	ADDC/LVSGC/16/4576892382	1-Feb-2016	1-Feb-2019					
29		1600A MDB with 1000A ACB, TP Merlin Gerin Make	1600A 2x60x10								







1	A	B	C	D	E	F	G
2			ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List				
3							
4							
5	Manufacturer Name & Address						
6	Sr. No.	Approved Model/Type of Assenbly with Current Rating			ADDC Approval Letter Reference	Date of	
7		Product Reference		Current Rating/ Busbar Size		Approval /	Expiry
8							
9	A Product Group LV01 - MDB, SMDB and Final DB						
241							
242	26	Faisal Jassim Trading LLC			Tel: 04-810 5105, Fax: 04-810 5106		
243		3200A PROMASTER SWITCHBOARD (3200A ACB ABB Sace Emax 3-Pole type E4H 32 + PR121/P)		3200A 2x100x10	ADDC/LVSGC/16/4322715197	6-Nov-2016	6-Nov-2019
244		2500A PROMASTER SWITCHBOARD 2500A ACB (ABB)		2500A 3x500x10	ADDC/LVSGC/16/4322715197	6-Nov-2016	6-Nov-2019
245		630A PROMASTER SWITCHBOARD 630A MCCB (ABB)		630A 1x50x10	ADDC/LVSGC/16/6798905498	6-Nov-2016	6-Nov-2019
246		400A PROMASTER SWITCHBOARD 400A MCCB (ABB)		400A 1x30x10	ADDC/LVSGC/16/6798905498	6-Nov-2016	6-Nov-2019
247		250A PROMASTER SWITCHBOARD 250A MCCB (ABB)		250A 1x20x10	ADDC/LVSGC/16/6798905498	6-Nov-2016	6-Nov-2019
248							
249							
250	27	Federal Switchgear Ltd			Tel: 02-631 8044, Fax: 02-631 8007		
251		FedSafe - MDB Form4System- Incomer : ACB Metasol, LS Industrial AN- 13D3-13A - Outgoings : MCCB, LS Industrial System		1200A 2x80x5	ADDC/LVSGC/ 16/7268091212	6-Nov-2016	6-Nov-2019
252		FedSafe - MDB Form4System - Incomer : ACB Metasol, LS Industrial AS- 20E3 -20A - Outgoings : MCCB, LS Industrial System		1800A 2x2x80x5			
253							
254	28	Gama Engineering			Tel: 06-598 1999, Fax: 06-598 900		
255		800A GAMA LV with 800A MCCB, TP schneider Make		800A 1x50x10	ADDC/LVSGC/16/2540039527	1-Mar-2016	1-Mar-2019
256		1600A GAMA LV Switchboard with 1600A ACB, TP schneider Make		1600A 2x60x10			
257		2500A GAMA LV Switchboard with 2500A ACB, TP schneider Make		2500A 2x100x10			
258		4000A GAMA LV Switchboard with 4000A ACB, TP schneider Make		4000A 3x120x10			
259							
260	29	General Electric International Inc.			Tel: 04-313 1839, Fax: 04-331 0053		
261		SEN System		1760A	ADDC/LVSGC/8079238083	1-Feb-2016	11-Feb-2019
262		SEN Plus 2500A Incoming with 2500 ACB MPACT PLUS, SEN Plus Make		2x50x10 IP42			
263		SEN System		2200A			
264		SEN Plus 2500A Incoming with 2500 ACB 3P, SEN Plus Make		50x10 IP42			
265		SEN System		2200A			
266		SEN Plus 5000A Incoming with 2500A ACB MPACT PLUS, SEN Plus Make		2(3x100x10) IP54			


A	B	C	D	E	F	G
1						
2						
3						
4						
5						
6						
7						
8						
9	A	Product Group LV01 - MDB, SMDB and Final DB				
264	30	Gulf Dynamic Switchgear Co. LLC		Tel: 06-533 8568, Fax: 06-533 6383		
265		3200A Panel Form 4 With 3200A ACB, TP Mitsubishi Make	3200A 2x120x10			
266		DYNAMIC 160S	1600A			
267		1600A Panel Form 4 With 1600A ACB, TP Mitsubishi Make	2 x 60 x 10	ADDC/LVSGC/16/3822817089	1-Feb-2016	1-Feb-2019
268		DYNAMIC 40S	400A			
269		400A Panel Form 2 With 400A MCCB, TP Mitsubishi Make	1 x 30 x 10			
270		DYNAMIC 25S	250A			
271		250A Panel Form 4 With 250A MCCB, TP Mitsubishi Make	1 x 20 x 10	ADDC/LVSGC/16/7379450036	1-Mar-2016	1-Mar-2019
272		DYNAMIC 63S	630A			
273		630A 63M, SMDB IP54,50kA, 1S, With Incomer 630A MCCB Mitsubishi Make	1 x 40 x 10	ADDC/LVSGC/16/6483921038	1-Feb-2016	1-Feb-2019
274		DYNAMIC 250S	2500A			
275		2500A Panel Form 4, with 2500A ACB, TP Mitsubishi Make	2 x 100 x 10	QCC APPROVAL LETTER	4-Feb-2018	3-Feb-2019
276		DYNAMIC 400S	4000A			
277		4000A DB (ACB Schneider)	3 x 120 x 10			
278		DYNAMIC 100S	1000A			
279		1000A DB (MCCB Schneider)	1 x 60 x 10			
280	31	Hager M.E. FZE		Tel: 04-883 6364, Fax: 04-883 7993		
281		125A TPN FDB - Split Busbar	60A			
282		(Switch Disconnecter 125A, Hager)	13.5x3.5	ADDC/LVSGC/14/4705607104	16-Mar-14	16-Mar-17
283		125A TPN DB - Single Busbar	95A			
284		(Switch Disconnecter 125A, Hager)	13.5x3.5			
285		250A TPN DB - Single Busbar	150A			
286		(MCCB 250A, Hager)	13.5x3.5	QCC APPROVAL LETTER	4-Feb-18	3-Feb-19
287		INVICTA TPN 125A ,HAGER	100A 1 x13.5 x 3.5			
288		INVICTA TPN 250A ,HAGER	200A 1 x13.5 x 3.5			
289		INVICTA TPN 125A , SPLIT LOAD ,HAGER	100A 1 x13.5 x 3.5			
290	32	Illumination Centre Electrical contc.Est.		Tel: 02-6329 800, Fax: 02- 6325 494		
291		Servo Series 2500 MDB With 2500A TP ACB , Schneider Make	2500A 2 x 100 x 10	QCC APPROVAL LETTER	4-Mar-18	3-Mar-19
292		Servo Series 1600 MDB With 1600A TP ACB , Schneider Make	1600A 2 x 60 x 10			
293		Servo Series 1000 DB With 1000A TP ACB , Schneider Make	1000A 1 x 100 x 10			
294		Servoline 800 SMDB With 800A TP MCCB , Schneider Make	800A 2 x 50 x 5			
295		Servoline 400A SMDB With 400A T P MCCB , Schneider Make	400A 1 x 60 x 5			
296		Servoline 250A SMDB With 250A T P MCCB , Schneider Make	250A 1 x 40 x 5			
297		Servo Straight 250A SMDB With 250A T P MCCB , Schneider Make	250A 1 x 15x 5			
298		Servo Splitt 125A SMDB With 250A T P MCCB , Schneider Make	250A 1 x 15x 3			






1	A	B	C	D	E	F	G
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List					
3		Manufacturer Name & Address					
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		ADDC Approval Letter Reference	Date of Approval / Expiry	
5			Product Reference	Current Rating/ Busbar Size			
6	A Product Group LV01 - MDB, SMDB and Final DB						
7	33	Larsen & Toubro Limited			Tel: 02-676 5988, Fax: 02-676 6399		
8		FDB 125 Split Type, 14 +6 way , L&T	125A 1x12.5x3.5	ADDC/LVSGC/17/1774113483	17-Sep-2017	16-Sep-2020	
9		FDB 125 Split Type, 16 way , L&T	125A 1x12.5x3.5				
10		1000A SMDB TYPE TS+TX Form 4b Type 6	1000A 1x50x10	QCC APPROVAL LETTER	12-Dec-2017	11-Dec-2018	
11		2500A MDB TYPE TS+TX F	2500A 2x100x10				
12		2500A MDB TYPE ENERSYS M , ACB	2500A 2x100x10				
13	2500A MCC TYPE TS-TX	4000A 2x150x10					
14	34	LS Industrial System			Tel: 04-8865 360, Fax : 04- 8865 361		
15	LS Industrial System	1600A MODULAR PANEL ACB, LS MAKE	1600A 2x10x60	ADDC/LVSGC/17/79783856393 & 75519436369	17-Sep-2017	16-Sep-2020	
16		2500A MODULAR PANEL ACB, LS MAKE	2500A 2x10x100				
17		4000A MODULAR PANEL ACB, LS MAKE	4000A 4x10x100				
18	35	MAX Electrical Control System Ind. L.L.C			Tel: 06-575 6722		
19	MAX Electrical Control System Ind. L.L.C	2500A MCS SYSTEM with 2500A ACB(ABB) IP 43	2500A 2 x 100 x 10	ADDC/LVSGC/16/6523141146	5-Dec-2016	5-Dec-2019	
20		1600A MCS SYSTEM with 1600A ACB(ABB) IP 43	1600A 1 x 100 x 10				
21		1250A MCS SYSTEM with 1250A MCCB(ABB) IP 43	1250A 2 x 40 x 10				
22		800A MCS SYSTEM with 1000A MCCB(ABB) IP 43	800A 1x50x10				
23		400A MCS SYSTEM with 630A MCCB(ABB) IP 43	400A 1x30x10				
24		250A MCS SYSTEM with 320A MCCB(ABB) IP 43	250A 1x20x10				
25	36	Matrix Switchgear Industries L.L.C			Tel: 06-543 9391, Fax: 06-543 9392		
26	Matrix Switchgear Industries L.L.C	LV Panel 2500A Extendable 6 outgoing MCCB (3200A ACB)	2500A 2 x 100 x 10	ADDC/LVSGC/17/7600823462	23-Feb-2017	22-Feb-2020	
27		LV Panel 1600A Extendable 6 outgoing MCCB (2000A ACB)	1600A 2 x 60 x 10				
28		250 A SMDB - 6 WAY with 250A MCCB, TO ABB Make	250A 1x25x5	ADDC/LVSGC/16/3571208035 & 4286299434	1-Feb-2016	1-Feb-2019	
29		400 A SMDB - 6 WAY with 400A MCCB, TO ABB Make	400A 1x30x10				
30		800A SMDB -8 WAY with 800A MCCB, TO ABB Make	800A 1x50x10				
31	3200A -LV SWITCHBOARD KA-1 SECOND-FORM with 4000A ACB, TO ABB Make	3200A 3x120x10					


A	B	C	D	E	F	G
1						
2						
3						
4	شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.					
5						
6						
7						
8						
9	A	Product Group LV01 - MDB, SMDB and Final DB				
321						
322	37	M.A.H.Y.Khoory & Co L.L.C	P.O. Box	Tel: 04-265 9875, Fax: 04- 268 2999		
323		250A SMDB With 320A MCCB (ABB), 36kA/ 1Sec	250A 1x30x10			
324		400A SMDB With 630A MCCB (ABB), 36kA/ 1Sec	400A 1x30x10			
325		630A SMDB With 800A MCCB (ABB), 50kA/ 1Sec	630A 1x40x10			
326	M.A.H.Y.KHOORY & CO L.L.C	1000A SMDB/MCC With 1250A MCCB (ABB), 50kA/ 1Sec	1000A 1x60x10	ADDC/LVSGC/16/0499699709	15-Nov-2016	15-Nov-2019
327		1600A MDB With 1600A ACB (ABB), 50kA/ 3Sec	1600A 2x60x10			
328		2500A MDB With 2500A ACB (ABB), 50kA/ 3Sec	2500A 2x100x10			
329		3200A MDB With 3200A ACB (ABB), 65kA/ 3Sec	3200A 3x90x10			
330		4000A MDB With 4000A ACB (ABB), 65kA/ 3Sec	4000A 4x90x10			
331						
332	38	Max Electrical Control System		Tel: 06-575 6722		
333		250A MCS WITH 320A MCCB , ABB	250A 1x20x10			
334		400A MCS WITH 630A MCCB , ABB	400A 1x30x10			
335		800A MCS WITH 1000A MCCB , ABB	800A 1x50x10	ADDC/LVSGC/16/6523141146	5-Dec-2016	4-Dec-2019
336		1250A MCS WITH 1250A MCCB , ABB	1250A 2x40x10			
337		1600A MCS WITH 1600A ACB , ABB	1600A 1x100x10			
338		2500A MCS WITH 2500A ACB , ABB	2500A 2x100x10			
339						
340	39	MoonStar Electrical Switchgear L.L.C		Tel: 04 - 880 3081		
341		160A SMDB NON EXTENDABLE ,MCCB , ABB	160A 1x20x5			
342		250A SMDB NON EXTENDABLE ,MCCB , ABB	250A 1x20x10	ADDC/LVSGC/17/7892792871	12-Feb-2017	11-Feb-2020
343		400A SMDB NON EXTENDABLE ,MCCB , ABB	400A 1x30x10			
344		800A SMDB NON EXTENDABLE ,MCCB , ABB	800A 1x50x10			
345		400A Draw Out MCC with 400A MCCB , ABB MAKE	400A 2 x 20 x 10	ADDC/LVSGC/16/4290914405		
346		1600A MDB with 1600A ACB , ABB MAKE	1600A 2 x 60 x 10	ADDC/LVSGC/16/7046519457	25-Oct-2016	25-Oct-2019
347		2500A MDB with 2500A ACB , ABB MAKE	2500A 2 x 100x 10			




A	B	C	D	E	F	G
1						
2						
3						
4	شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.					
5						
6						
7						
8						
9	A	Product Group LV01 - MDB, SMDB and Final DB				
348						
349	40	Musandam Electrical Equipment LLC		Tel: 02-642 4471, Fax: 02-642 5257		
350		2500A LV Distribution Board (2500A ACB Schneider)	2500A 4 x 100 x 5			
351		1600A LV Distribution Panel Schneider ACB type,	1600A 3 x 80 x 5			
352		1250A LV Distribution Panel Schneider ACB type	1250A 2 x 80 x 5			
353		800A LV Distribution Panel Schneider MCCB	800A 2 x 40 x 5	QCC APPROVAL LETTER	9-Apr-2018	8-Apr-2019
354		400A LV Distribution Panel Schneider MCCB	400A 2 x 40 x 5			
355		250A LV Distribution Panel Schneider MCCB	250A 2 x 40 x 5			
356		250A ATS	250A 2 x 40 x 5			
357		400A ATS	400A 2 x 40 x 5			
358						
359						
360						
361	41	Pacific Ocean Electrical Switchgear Industries LLC		Tel: 06-534 5334, Fax: 06-534 7212		
362		4000A MDB	4000A			
363		ACB = 5000A (Schneider)	4x100x10			
364		2500A MDB	2500A	ADDC/LVSGC/16/4193345451	5-Dec-2016	5-Dec-2019
365		ACB = 2500A (Schneider)	2x80x10			
366		1600A MDB	1600A			
367		ACB = 1600A (Schneider)	2x50x10			
368		800A MDB	800A	QCC APPROVAL LETTER	4-Mar-2018	3-Mar-2019
369		MCCB (Schneider)	1x50x10			
370		400A SMDB	400A			
371		MCCB (Schneider)	1x30x10			
372		800A MDB	800A			
373		MCCB (Schneider)	1x50x10			
374		400A SMDB	400A	ADDC/LVSGC/8271028730	5-Dec-2016	5-Dec-2019
375		MCCB (Schneider)	1x30x10			
376		2500A MDB Extendable	2500A			
377		ACB = 2500A (ABB)	2x80x10			
378		2500A I shape				
379		ACB = 2500A (ABB)				
380						
381						
382	42	Power and Control FZCO	P.O. Box	Tel: 04-883 0391, Fax: 04-883 0392		
383		LV Switchboard Form 4b	2500A			
384		2500A (ACB Emax E3N25 ABB Sace)	2x100x10	ADDC/LVSGC/17/5756269439	14-Sep-2017	13-Sep-2020
385		LV Switchgear, Form 2b Type 2	1000A			
386		1000A (MCCB TTS 1000 ABB)	2x30x10			
387		LV Switchgear, Form 2b Type 2	400A			
388		400A (MCCB TMAX TSS 400 ABB)	30x10			
389		LV Switchgear, Form 2b Type 2	250A			
390		250A (MCCB TMAX XT4N 250 ABB)	20x10			

1	A	B	C	D	E	F	G	
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List						
3		Manufacturer Name & Address						
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		Current Rating/ Busbar Size	ADDC Approval Letter Reference	Date of	
5			Product Reference	Approval /			Expiry	
6	Product Group LV01 - MDB, SMDB and Final DB							
7	43	Powerwell SDN. BHD.			Tel:+60355213383, Fax: +60351222933			
372		6000A MSB/MDB	5500A	ADDC/LVSGC/14/5483021744	21-Aug-14	20-Aug-17		
373		6300A 3-Pole ACB, ABB Sace Emax E6	3 x 150 x 10					
374		4000A MSB/MDB	3700A					
375		4000A 3-Pole ACB, ABB Sace Emax E6	3 x 150 x 10					
376		3200A MSB/MDB	3200A					
377		3200A 3-Pole ACB, ABB Sace Emax E4	2 x 110 x 10					
378		2500A MSB/MDB	2300A					
379		2500A 4-Pole ACB, ABB Sace Emax E3	2 x 85 x 10					
380		2000A MSB/MDB	1600A					
381		2500A 4-Pole ACB, ABB Sace Emax E3	2 x 85 x 10					
382	1600A MSB/MDB	1250A						
383	1600A 3-Pole ACB, ABB Sace Emax E2	2x55x10						
384	1250A MSB/MDB	1250A						
385	1600A 3-Pole ACB, ABB Sace Emax E2	2 x 55 x 10						
386	44	Power Dynamic Switchgear Est.			Tel: 03-72 20260 , Fax: 03-72 20290			
387		400A SMDB IP43, 1S With 400A MCCB, TP Schneider Make	400A 1x30x10	ADDC/LVSGC/16/4611236222	1-Mar-2016	1-Mar-2019		
388		630A SMDB IP43, 1S With 630A MCCB, TP Schneider Make	630A 1x40x10					
389		1000A SMDB IP43, 1S With 1250A MCCB, TP Schneider Make	1000A 2x40x10					
390								
391								
392	45	POWERTECH Switchgear Industries F.Z.E			Tel: 06-7472274, Fax: 06-7472551			
393		250A SMDB with 250A MCCB , TP, ABB Make Non-extendable	250A	ADDC/LVSGC/16/6172507470	1-Mar-2016	1-Mar-2019		
394		10 outgoing MCCB	2x10x10					
395		400A SMDB with 400A MCCB , TP, ABB Make Non-extendable	400A					
396		10 outgoing MCCB	2x15x10					
397		630A SMDB with 630A MCCB , TP, ABB Make Non-extendable	630A					
398		18 outgoing MCCB	2x25x10					
399		800A MCC with 800A MCCB , TP, ABB Make withdrawable	800A					
400		Extendable	1x60x10					
401								
402	46	Prime Electrical Manufacturing LLC			Tel: 04-453 1666, Fax: 04-453 1662			
403		PRIMA S1600 MDB 6 way Panel	1600A	ADDC/LVSGC/17/7270705145	2-May-17	1-May-20		
404		TP ACB, NW16 Schneider Electric	2 x 60 x 10					
405		PRIMA S2500 MDB 6 way Panel	2500A					
406								
407	47	Prisma Electric Switchgear Ind.L.L.C			Tel: 06-533 2396, Fax: 6-533 1362			
408		400A Enersteel Plus System with 400A SMDB, IP54-INCOMER 400A MCCB ,	400A	ADDC/LVSGC/16/0897298831	19-Jun-16	19-Jun-19		
409		50kA/1sec , Schneider Make	1 x 30 x 10					
410		800A Enersteel Plus System with 800A MDB, IP54-INCOMER 800A MCCB ,	800A					
411		50kA/1sec , Schneider Make	1 x 50 x 10					

A	B	C	D	E	F	G
1						
2						
3						
4						
5						
6						
7						
8						
9	A	Product Group LV01 - MDB, SMDB and Final DB				
412	48	Safe Line Electrical & Mehcnaiical LLC		Tel: 02-650 4999, Fax: 02-650 4998		
413						
414		2500A LV Panel (ACB Schneider)	2500A 2 x 100 x 10			
415		1600A LV Panel (ACB Schneider)	1600A 2 x 60 x 10			
416		1000A LV Panel (MCCB Schneider)	1000A 2 x 40 x 10	ADDC/LVSGC/16/4798467570	12-Oct-2016	12-Oct-2019
417		800A LV Panel (MCCB Schneider)	800A 1 x 50 x 10			
418		400A LV Panel (MCCB Schneider)	400A 1 x 30 x 10			
419		250A LV Panel (MCCB Schneider)	250A 1 x 20 x 10			
420		1250A LV Panel (ACB Schneider)	1250A 2 x 40 x 10	ADDC/LVSGC/17/3248210793	23-Jul-2017	22-Jul-2020
421						
422	49	Safety Electrical Trading		P.O. Box Tel: 02-628 2707, Fax: 02-628 2708		
423						
424		250A PANEL BOARD FBA (Non-Extendable) (250A MCCB GE Type: FG 250 Record Plus)	250A 2x5x5			
425		1250A PANEL BOARD FBA FORM 4 EXTENDABLE (1250A ACB GE Type: MPACT PLUS)	1250A 2x40x10	ADDC/LVSGC/16/2892532122	6-Nov-2016	6-Nov-2019
426		1600A PANEL BOARD FBA FORM 4 EXTENDABLE (1600A ACB GE Type: MPACT PLUS)	1600A 2x60x10			
427		2500A PANEL BOARD FBA FORM 4 EXTENDABLE (2500A ACB GE Type: MPACT PLUS)	2500A 2x100x10			
428	50	Sara Electrical Supplies Est		P.O. Box Tel: 02-679 3929, Fax: 02-679 3989		
429						
430		SR04 - 400A MDB/SMDB/MCC/ ATS/Cap. Bank	400A 1x60x5			
431		SR08 - 800A MDB/SMDB/MCC/ ATS/Cap. Bank	800A 2x50x5			
432		SR10 - 1000A MDB/SMDB/MCC/ ATS/Cap. Bank (ACB Incomer)	1000A 2x80x10	ADDC/LVSGC/16/1491857411	1-Feb-2016	1-Feb-2019
433		SR16 - 1600A MDB/SMDB/MCC/ ATS (ACB Incomer)	1600A 2x60x10			
434		SR25 - 2500A MDB/SMDB/MCC/ ATS (ACB Incomer)	2500A 2x100x10			

A	B	C	D	E	F	G
1						
2						
3						
4	شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.					
5						
6						
7						
8						
9	A	Product Group LV01 - MDB, SMDB and Final DB				
435	51	Schneider Electric FZE	P.O. Box	Tel: 04-808 7100, Fax: 04-808 7101		
436		1600A Prisma TT With 1600A ACB 3P , Merlin Gerin Make	1600A 2x60x10		ADDC/LVSGC/16/2215250564	1-Feb-2016 1-Feb-2019
437		2500A Prisma TT With 2500A ACB 3P , Merlin Gerin Make	2500A 2x100x10			
438		3200A Prisma TT With 3200A ACB 3P , Merlin Gerin Make	3200A 2x150x10			
439						
440		Disbo Extra DB Split DB with 125A Disconnecter , schneider Make	125A 10x5		ADDC/LVSGC/16/7403427316	3-Feb-2016 3-Feb-2019
441		Disbo Extra DB Final DB with 125A DB , schneider Make	125A 10x5			
442		Powerline 250A SMDB with 250A MCCB 3P+N, Schneider Make	250A 1x40x2 (L1 ,L3) 1x33x2 (L2)		ADDC/LVSGC/16/8334093565	25-Oct-2016 25-Oct-2019
443		Powerline 400A SMDB with 400A MCCB 3P, Schneider Make	400A 1x189x2 (L1 ,L3) 1x165x2 (L2)			
444		Powerline 630A SMDB with 630A MCCB 3P, Schneider Make	630A 1x189x3 (L1 ,L3) 1x165x3 (L2)			
445		Powerline Plus - 14ways 250A MDB/SMDB	250A 20x10		ADDC/LVSGC/16/8334093565	3-Feb-2016 3-Feb-2019
446		Powerline Plus - 14ways 400A MDB/SMDB	400A 30x10			
447		Powerline Plus - 14ways 630A MDB/SMDB	620A 2x30x10			
448		Powerline Plus - 14ways 800A MDB/SMDB	800A 2x30x10			
449		Disbo Extra Distribution Board (250A) (250A MCCB Schneider NSX 250N)	250A 15x5		ADDC/LVSGC/16/2265815295 (1. This material is approved as Final Distribution Board (FDB) only)	25-Oct-2016 25-Oct-2019
450		BLOKSET-1600A	1600A 2x100x5		ADDC/LVSGC/16/3682600964	25-Oct-2016 25-Oct-2019
451		BLOKSET-2500A	2500A 4x100x5			
452		BLOKSET-3200A	3200A 5x125x5			
453		BLOKSET-4000A	4000A 8x100x5			
454		BLOKSET-6000A	6000A 10x100x5			
455		Disbo Extra Distribution Board (250A) (250A MCCB Schneider NSX 250N)	250A 15x5		ADDC/LVSGC/16/7403427316	3-Feb-2016 3-Feb-2019
456		Disbo Extra DB-Split Busbar with 125A Switch Disconnecter	100A 12.4x3.15 Link/ 10x3		ADDC/LVSGC/16/2411215366	25-Oct-2016 25-Oct-2019
457		Disbo Extra DB-Split Busbar with 115A Switch Disconnecter	115A 12.4x3.15 Link/ 10x3			

1	A	B	C	D	E	F	G	
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List						
3		Manufacturer Name & Address						
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		Current Rating/ Busbar Size	ADDC Approval Letter Reference	Date of	
5			Product Reference	Approval /			Expiry	
6	A Product Group LV01 - MDB, SMDB and Final DB							
7	52	Sea Breeze Elect.Switchgear			Tel: 06 - 5355 993, Fax: 06- 5355 994			
8	SEA BREEZE	400A SMDB NON EXTENDABLE WITH 400A MCCB , SCHNEIDER		400A 1x30x10	ADDC/LVSGC/17/6317932317	2-May-2017	1-May-2020	
9	53	Shintech Electrical & Mechanical Equipment			mob: 055-3646745			
10	SHINTECH ELECTRICAL	250A LV PANEL FORM 2b ,MCCB, SCHNEIDER		250A 1x20x10	QCC APPROVAL LETTER	11-Sep-2018	10-Sep-2019	
11		400A LV PANEL FORM 2b ,MCCB, SCHNEIDER		400A 1x30x10				
12		800A LV PANEL FORM 2b ,MCCB, SCHNEIDER		800A 1x50x10				
13		1250A LV PANEL MCCB FORM 2b ,SCHNEIDER		1250A 2x40x10				
14		1250A LV PANEL ACB FORM 2b ,, SCHNEIDER		1250A 2x40x10				
15		1250A LV PANEL ACB FORM 4b Type 6,SCHNEIDER		1600A 2x60x10				
16		2500A LV PANEL ACB FORM 4b Type 6,SCHNEIDER		2500A 2x100x10				
17	54	Start Electrical Switchgear Assembly L.LC			Tel: 06 - 535 8223, Fax: 06- 535 8211			
18	START ELECTRICAL	START TT 1600A with 400A MCCB ,COMPACT. Schneider Make		400A 1x30x10	QCC APPROVAL LETTER	16-Jan-2018	15-Jan-2019	
19		START TT 1600A with 800A MCCB NS800N,COMPACT. Schneider Make		800A 1x50x10				
20		START TT 1600A with 1600A ACB ,MASTERPACT. Schneider Make		1600A 2x60x10				
21		START TT 2500A with 2500A ACB NW251,MASTERPACT. Schneider Make		2500A 2x100x10				
22	55	Simpsons Electrical Switchgear			Tel: 04-886 7881, Fax: 02-886 7881			
23	SIMPSON ELECTRICAL	125A SIM SLEEK SPLIT DB WITH 100A MCCB , SCHNEIDER		100A 1x15x3	QCC APPROVAL LETTER	16-Jan-2018	15-Jan-2019	
24		250A SIM SLEEK SPLIT DB WITH 225A MCCB , SCHNEIDER		225A 1x15x5				
25		250A SIM PROTECT SMDB WITH 250A MCCB , SCHNEIDER		250A 1x40x5				
26		400A SIM PROTECT SMDB WITH 400A MCCB , SCHNEIDER		400A 1x60x5				
27		800A SIM PROTECT SMDB WITH 800A MCCB , SCHNEIDER		800A 2x50x5				
28		1200A SIM PROTECT MDB WITH 1200A ACB , SCHNEIDER		1200A 2x50x10				
29		1600A SIM PROTECT MDB WITH 1600A ACB , SCHNEIDER		1600A 2x60x10				
30		2500A SIM PROTECT MDB WITH 2500A ACB , SCHNEIDER		2500A 2x100x10				


1	A	B	C	D	E	F	G	
2	 شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	ABU DHABI DISTRIBUTION COMPANY Approved Low Voltage Switchgear Vendor List						
3		Manufacturer Name & Address						
4		Sr. No.	Approved Model/Type of Assenbly with Current Rating		Current Rating/ Busbar Size	ADDC Approval Letter Reference	Date of	
5			Product Reference	Approval /			Expiry	
6	Product Group LV01 - MDB, SMDB and Final DB							
7	59	Verger et Delporte UAE Ltd		P.O. Box Tel: 06-543 2436, Fax: 06-543 4139				
8		CAMGRO F1 SYSTEM - Split FDB with 125A Isolator / RCB , TP SCHENIDER MAKE	15x3	125A	ADDC/LVSGC/16/8038819450	1-Mar-16	1-Mar-19	
9		CAMGRO F2 SYSTEM - FDB with 250A MCCB, TP SCHENIDER MAKE	250A	15x5				
10		CAMGRO S1 SYSTEM - SMDB with 250A MCCB, TP SCHENIDER MAKE	250A	40x5				
11		CAMGRO S2 SYSTEM - SMDB with 400A MCCB, TP SCHENIDER MAKE	400A	60x5				
12		CAMGRO S3 SYSTEM - SMDB with 630A MCCB, TP SCHENIDER MAKE	630A	2x50x5				
13		CAMGRO S4 SYSTEM - SMDB with 800A MCCB, TP SCHENIDER MAKE	800A	2x50x5				
14		CAMGRO SYSTEM -MDB with 1000A ACB, TP SCHENIDER MAKE	1000A	2x60x5				
15		CAMGRO SYSTEM -MDB with 1600A ACB, TP SCHENIDER MAKE	1600A 2x100x5					
16		CAMGRO SYSTEM -MDB with 2500A ACB, TP SCHENIDER MAKE	2500A	4x100x5				
17		250A SMDB , MCC with 250A MCCB, TP SCHENIDER MAKE	250A 1x60x5					
18	630A MDB , MCC with 630A MCCB, TP SCHENIDER MAKE	630A 1x100x5						
19	3200A MDB , MCC with 3200A ACB, TP SCHENIDER MAKE	3200A 5x125x5						
20	CAMGRO SYSTEM- 4000A Main Distribution Board/MCC	4000A 2 (4x100x5)						
21	CAMGRO SYSTEM- 6000A Main Distribution Board/MCC	6000A 2 (5x100x5)						
22	60	Voltage Elec. Switchgear Ind. Co. LTD		P.O. Box Tel: 06-5329979, Fax: 06-5329313				
23	 Voltage Elec. Switchgear Ind. Co. Ltd.	100A FDB SPLIT TYPE With 125A Switch Disconnecter, TP SIEMENS MAKE	100A 1 x10 x 4		QCC APPROVAL LETTER	4-Feb-2018	3-Feb-2019	
24		400A SMDB with 400A MCCB,TP SIEMENS MAKE	400A 1 x 30 x 10					
25		800A SMDB with 800A MCCB,TP SIEMENS MAKE	800A 1 x 50 x 10					
26		1250A SMDB with 1600A MCCB,TP SIEMENS MAKE	1250A 2 x 50 x 10					
27		1600A MDB with 1600A ACB,TP SIEMENS MAKE	1600A 2 x 60 x 10					
28		2500A MDB with 3200A ACB,TP SIEMENS MAKE	2500A 2 x 100 x 10					
29		MDB 4000A (ACB 5000A Siemens Czech Republic)	4000A 3x100x10					



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Co.

ABU DHABI DISTRIBUTION COMPANY

Approved LV Automatic Transfer Witches Vendor List

Sr. No.	Manufacturer Name & Address					
	Approved Model/Type of Assenly with Current Rating			ADDC Approval Letter Reference	Date of Approval / Expiry	
	Product Reference	Current Rating/ Busbar Size	Country of Origin			
B Product Group LV02 - Automatic Transfer Switches (ATS)						
2	Bin Ghalib	P.O. Box 44635, Abu Dhabi		Tel: 02-679 4026, Fax: 02- 679 5934		
	250A Automatic Transfer Switch (SCHNEIDER)	250A 1 x 20 x 10	UNITED ARAB EMIRATES	ADDC/LVSGC/17/6538817899	12-Feb-2017	12-Feb-2020
	400A ATS Automatic Transfer Switch (SCHNEIDER)	400A 1 x 30 x 10				
	800A Automatic Transfer Switch (SCHNEIDER)	735A 1 x 50 x 10				
	1340A Automatic Transfer Switch (SCHNEIDER)	1340A 1 x 50 x 10				
	2000A Automatic Transfer Switch (SCHNEIDER)	2000A 2 x 100 x 10				



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY

Approved Low Voltage Bus Risers Vendor List

Manufacturer Name & Address						
Sr. No.	Approved Model/Type of Assembly with Current Rating			ADDC Approval Letter Reference	Date of Approval / Expiry	
	Product Reference	Current Rating/ Busbar Size	Country of Origin			
C	Product Group LV03 - LV Bus Riser/ Trunking System					
1	Emirates Technical association		P.O. Box 9677, Dubai		Tel: 06-557 4060, Fax: 06-557 4020	
ETA	KXC 10	800A 6x55	TURKEY	ADDC/LVSGC/17/8568719236	23-Feb-2017	22-Feb-2020
	KXC 12	1000A 6x 70				
	KXC 14	1000A 6x 80				
	KXC 16	1350A 6x110				
	KXC 20	1600A 6x140				
	KXC 25	2000A 6x200				
	KXC 32	2500A 2x6x110				
	KXC 36	3000A 2x6x125				
	KXC 40	3200A 2x6x140				
	KXC 50	4000A 2x6x200				
	KXC 63	63000A 3x6x200				
	Tap Offs - KXP 1650	160A				
	Tap Offs - KXP 2550	250A				
	Tap Offs - KXP 4050	350A				
	Tap Offs - KXP 6350	515A				
	Tap Offs - KXP 6351	590A				
2	Gersan Elektrik Tic.Ve. San.A.S		P.O. Box 9677, Dubai		Tel: 06-557 4060, Fax: 06-557 4020	
	GS 1000A 3PH N+PE (Housing)	1000A 55x 6				
	GS 1250A 3PH N+PE (Housing)	1250A 75x 6				
	GS 1600A 3PH N+PE (Housing)	1350A 110x6				



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY

Approved Low Voltage Bus Risers Vendor List

Sr. No.	Manufacturer Name & Address					
	Approved Model/Type of Assenbly with Current Rating			ADDC Approval Letter Reference	Date of Approval / Expiry	
	Product Reference	Current Rating/ Busbar Size	Country of Origin			
C Product Group LV03 - LV Bus Riser/ Trunking System						
GERSAN ELEKRIK	GS 2000A 3PH N+PE (Housing)	2000A 130x8	TURKEY	ADDC/LVSGC/16/2113074586	1-Mar-2016	1-Mar-2019
	GS 2500A 3PH N+PE (Housing)	2250A 2x180x6				
	GS 3200A 3PH N+PE (Housing)	2700A 2x130x6				
	GS 4000A 3PH N+PE (Housing)	4000A 2x180x6				
	GS 5000A 3PH N+PE (Housing)	5000A 3x130x6				



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY

Approved Low Voltage Bus Risers Vendor List


Sr. No.	Manufacturer Name & Address				ADDC Approval Letter Reference	Date of Approval / Expiry
	Approved Model/Type of Assenbly with Current Rating			Country of Origin		
	Product Reference	Current Rating/ Busbar Size				
C	Product Group LV03 - LV Bus Riser/ Trunking System					



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY

Approved Low Voltage Bus Risers Vendor List

Manufacturer Name & Address						
Sr. No.	Approved Model/Type of Assenbly with Current Rating			ADDC Approval Letter Reference	Date of Approval / Expiry	
	Product Reference	Current Rating/ Busbar Size	Country of Origin			
C Product Group LV03 - LV Bus Riser/ Trunking System						
4	Power Plug Busduct SDN BHD			P.O. Box 11549, Dubai, UAE		Tel: 04-267 3797, Fax: 04-267 3139
 PPB	Powerduct 1000A (Copper)	800A 60 x 6	Power Plug Busduct Sdn. Bhd/ Malaysia	ADDC/LVSGC/16/4547708558	25-Jul-2016	24-Jul-2019
	Powerduct 1200A (Copper)	1000A 75 x 6				
	Powerduct 1350A (Copper)	1000A 90 x 6				
	Powerduct 1600A (Copper)	1350A 120 x 6				
	Powerduct 2000A (Copper)	1600A 150 x 6				
	Powerduct 2500A (Copper)	2000A 200 x 6				
	Powerduct 3000A (Copper)	2500A 2x125x6				
	Powerduct 4000A (Copper)	3200A 2x150x6				



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY

Approved Low Voltage Bus Risers Vendor List

Manufacturer Name & Address						
Sr. No.	Approved Model/Type of Assenbly with Current Rating			ADDC Approval Letter Reference	Date of Approval / Expiry	
	Product Reference	Current Rating/ Busbar Size	Country of Origin			
C	Product Group LV03 - LV Bus Riser/ Trunking System					
	Powerduct 5000A (Copper)	4500A 2x200x6				
5	Schneider Electric FZE	P.O. Box 341057, Dubai		Tel: 04-709 9249, Fax: 04-709 9101		
	LV Busway System with TapOff - 1					
	800A	800A 1 x 64 x 6.35	CHINA	QCC APPROVAL LETTER	18-Feb-2018	17-Feb-2019
	1000A	1000A 1 x 76 x 6.35				
	1250A	1250A 1 x 102 x 6.35				
	1350A	1350A 1 x 114 x 6.35				
	1600A	1600A 1 x 137 x 6.35				
	2000A	2000A 1 x 165 x 6.35				
	2500A	2500A 2 x 114 x 6.35				
	3000A	3000A 2 x 127 x 6.35				
	3200A	3200A 2 x 152 x 6.35				
	4000A	4000A 3 x 114 x 6.35				
	5000A	5000A 3 x 152 x 6.35				



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY

Approved Low Voltage Bus Risers Vendor List

Manufacturer Name & Address						
Sr. No.	Approved Model/Type of Assenbly with Current Rating			ADDC Approval Letter Reference	Date of Approval / Expiry	
	<i>Product Reference</i>	<i>Current Rating/ Busbar Size</i>	<i>Country of Origin</i>			
C	Product Group LV03 - LV Bus Riser/ Trunking System					
	LV Busway System with TapOff - 2					
	630A	630A 6.35x63.5	CHINA	ADDC/LVSGC/16/5833088448	13-Mar-2016	13-Mar-2019
	800A	800A 6.35x63.5				
	1000A	1000A 6.35x63.5				
	1250A	1250A 6.35x76.2				
	1350A	1350A 6.35x85.9				
	1600A	1600A 6.35x101.6				
	2000A	2000A 6.35x127.0				
	2500A	2500A 6.35x177.8				
	3200A	3200A 2x6.35x114.3				
	4000A	4000A 2x6.35x152.4				
	5000A	5000A 3 x 6.35 x 114.3				
	6300A	6300A 3x6.35x152.4				



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY



Approved LV Circuit Breaker Vendor List

Sr. No.	Manufacturer Name & Address				ADDC Approval Letter Reference	Date of Approval / Expiry
	Approved Model/Type of Assenbly with Current Rating			Country of Origin		
	Product Reference	Current Rating/ Busbar Size				
D Product Group LV04 - Circuit Breakers (ACB, MCCB, MCB, RCCB)						
1	Al Farraj Trading & Manufacturing Co.			P.O. Box 61122, Dubai, UAE Tel: 04-8833150, 04-		
	FTCP106H-FTCP163HFTCD106H FTCP106H-FTCP163HFTCD263H FTCP106H-FTCP163HFTCD306H FTCP106H-FTCP163HFTCD363H FTCP106H-FTCP163HFTCD206H FTCP106H-FTCP163HFTCD363H	6A to 63A (SP,DP,CTP)MCBS-Ctype	United Arab Emirates	ADDC/LVSGC/16/162 2586439	12-Jan-2017	12-Jan-2020
	FTCOP 1006A to 1040A FTCD 1006A to 1040A (30MA DP)	6A to 40A				
	FTCR 25A-63A 2 POLE 30, 100, 300m A (RCCB' S)	25A to 63A				
	FTCR 25A-63A 4 POLE	25A to 63A				
	FTCDK280, FTCDK2100 & FTCDK2125 (Switch disconnecter)	80A to 100A				
	FTCDK225, FTCDK232, FTCDK240, FTCDK250 &	25A to 63A				
	FTCDK325, FTCDK332, FTCDK340, FTCDK350 & FTCDK363	25A to 63A				
	FTCDK380, FTCDK3100 & FTCDK3125(Switch disconnecter)	80A to 100A				
	FTCG/ FTCGW (16A-100A), 25 kA	16A to 100A				
	FTCF/ FTCGW (16A-200A), 50kA	16A to 200A				
	FTCK/FTCKW, 50kA	315A to 400A				
	FTCL, 50kA (MCCB's)	500A to 630A				
	FTCJ3250, 65kA (MCCB's)	16A to 250A				
	FTCLG3630, 65kA (MCCB's)	400A TO 630A				
	FTCL3800, 65kA (MCCB's)	400A to 800A				



ABU DHABI DISTRIBUTION COMPANY



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

Sr. No.	Manufacturer Name & Address								
	Approved Model/Type of Assenbly with Current Rating					ADDC Approval Letter Reference	Date of Approval / Expiry		
	Product Group	Current Rating/ Busbar Size	Step rating (KVAR)	SC Rating (1 Sec.) (KA)	Range @440V (KVAR)				Country of Origin
E Product Group LV05 - Capacitor Bank									
1	3E Electrical Energy				P.O. Box	341084, Dubai, UAE	Tel: 04-3263950, Fax: 04-3263972		
	A	250A 1x20x10	6.25	25	5 to 75	United Arab Emirates Dubai	QCC APPROVAL LETTER	16-Feb-2018	15-Feb-2019
	A.1	250A 1x20x10	6.25	25	37.5 and below				
	B	630A 2x30x10	12.5	35	100 to 175				
	C	800A 2x30x10	25	50	200 to 375				
	D	1000A 2x30x10	25	50	400 and 450				
2	Al Terhab Elect.				P.O. Box	33674, Sharjah, UAE	Tel: 06-5345388, Fax: 06-5345385		
	A	250A 1x20x10	6.25	25	5 to 75	United Arab Emirates Sharjah	QCC APPROVAL LETTER	12-Dec-2017	11-Dec-2018
	B	630A 1x40x10	12.5	35	100 to 175				
	C	800A 1x50x10	25	50	200 to 375				
	D	1000A 1x60x10	25	50	400 and 450				



شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

ABU DHABI DISTRIBUTION COMPANY

Sr. No.	Manufacturer Name & Address								
	Approved Model/Type of Assenbly with Current Rating					Country of Origin	ADDC Approval Letter Reference	Date of Approval / Expiry	
	Product Group	Current Rating/ Busbar Size	Step rating (KVAR)	SC Rating (1 Sec.) (KA)	Range @440V (KVAR)				
E Product Group LV05 - Capacitor Bank									
3	Faisal Jassim Industries				P.O. Box	113825, Dubai, UAE		Tel: 04-8105105, Fax: 04-8105106	
	A.1	250A 1x20x10	6.25	25	5 to 25	United Arab Emirates Dubai	QCC APPROVAL LETTER	19-Jun-2018	18-Jun-2019
	A.2	250A 1x20x10	6.25	25	30 to 75				
	B	630A 1x50x10	12.5	35	100 to 175				
	D	1000A 2x50x10	25	50	400 to 450				
4	Gama Engineering				P.O. Box	8886, Sharjah, UAE		Tel: 06-5981999, Fax: 06-5981900	
	A	250A 1x30x10	6.25	25	5 to 75	United Arab Emirates Sharjah	QCC APPROVAL LETTER	16-Jan-2018	15-Jan-2019
	B	630A 2x30x10	12.5	35	100 to 175				
	C	800A 2x30x10	25	50	200 to 375				
	D	1000A 2x40x10	25	50	400 and 450				
5	Gulf Dynamic Switchgear				P.O. Box	6455, Sharjah, UAE		Tel: 02-6392211, Fax: 02-6392210	
Gulf Dynamic	D	590.5A 1x60x10	25	50	400 to 450	United Arab Emirates Sharjah	QCC APPROVAL LETTER	16-Jan-2018	15-Jan-2019
	C	492A 1x50x10	25	50	200 to 375				
	B	229.6A 1x40x10	12.5	35	100-175				




ABU DHABI DISTRIBUTION COMPANY

شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

Sr. No.	Manufacturer Name & Address						
	Approved Model/Type of Assenbly with Current Rating					ADDC Approval Letter Reference	Date of Approval / Expiry
	Product Group	Current Rating/ Busbar Size	Step rating (KVAR)	SC Rating (1 Sec.) (KA)	Range @440V (KVAR)		





E Product Group LV05 - Capacitor Bank

6					P.O. Box	2335, Ajman, UAE	Tel: 06-7472274, Fax: 06-7472551		
	A	250A 2x10x10	6.25	25	5 to 75	United Arab Emirates Ajman			
	B	630A 2x25x10	12.5	35	100 to 175				
	C	800A 2x25x10	25	50	200 to 375				
	D	1000A 2x30x10	25	50	400 to 450				
7	Safety Electrical Trading co . L.L.C				P.O. Box	27482, Abu Dhabi, UAE	Tel: 02- 555 9259 , Fax: 02- 555 9276		
Safety Electrical Trading co . L.L.C	A	250A 1x25x5	6.25	25	5 to 75	United Arab Emirates Dubai	QCC APPROVAL LETTER	16-Jan-2018	15-Jan-2019
	B	630A 1x30x10	12.5	35	100 to 175				
	C	800A 1x50x10	25	50	200 to 375				
	D	1000A 2x40x10	25	50	400 to 450				
	E	1000A 2x40x10	25	50	475 to 550				



ABU DHABI DISTRIBUTION COMPANY

شركة أبوظبي للتوزيع
Abu Dhabi Distribution Company

Sr. No.	Manufacturer Name & Address								
	Approved Model/Type of Assenbly with Current Rating					ADDC Approval Letter Reference	Date of Approval / Expiry		
	Product Group	Current Rating/ Busbar Size	Step rating (KVAR)	SC Rating (1 Sec.) (KA)	Range @440V (KVAR)				Country of Origin
E Product Group LV05 - Capacitor Bank									
8	Schneider Electric FZE				P.O. Box	17192, Dubai, UAE	Tel: 04-7099100, Fax: 04-7099101		
	C	800A 1x80x5	25	50	181 to 363	United Arab Emirates Dubai	QCC APPROVAL LETTER	1-Apr-2018	31-Mar-2019
	D	1000A 1x80x5	25	50	393 to 454				
	E	1000A 1x80x5	25	50	484 to 575				
9	Skyway Trading Co. LLC				P.O. Box	72946, Abu Dhabi, UAE	Tel: 02-6336576, Fax: 02-6315503		
	E	722A 2x40x10	25	50	450-550	United Arab Emirates Abu Dhabi	ADDC/LVSGC/16/72809 25155	30-May-2016	30-May-2019
10	Musandam Electrical				P.O. Box	4282, Abu Dhabi, UAE	Tel: 02-6424471, Fax: 02-6425257		
	B	630A 2x40x5	12.5	35	100 to 175	United Arab Emirates Abu Dhabi	QCC APPROVAL LETTER	18-Feb-2018	17-Feb-2019
	C	800A 2x40x5	25	50	200 to 375				
	D	1000A 2x40x5	25	50	400 to 450				
11	Voltage Elect.Switchgear Ind.Co.Ltd				P.O. Box	22154, Sharjah, UAE	Tel: 06--532 9979, Fax: 06-832 9313		
	B	229.6A / 30Xx10	12.5	35kA	100 to 175	United Arab Emirates Abu Dhabi	QCC APPROVAL LETTER	4-Feb-2018	3-Feb-2019
	C	492A / 2x30Xx10	25	50kA	200 to 375				
	D	590.5A / 2x40Xx10	25	50kA	400 to 450				